



2014 Annual Drinking Water Quality Report

City of Dowagiac, Michigan

Prepared May 2015

We are pleased to present to you the Annual Drinking Water Quality Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. In order to provide you with facts concerning Dowagiac's water supply we will be publishing this water quality report on an annual basis. Some general information on water supplies is included below.

How We Rate:

We're pleased to report that our drinking water is safe and meets all federal and state requirements. Our water is monitored on a regular basis for many different contaminants using both our in-house laboratories and the Michigan Department of Natural Resources and Environment laboratory. In a typical year well over 2,000 tests are performed to insure that proper chemical levels are maintained and to monitor for contaminants.

Additionally, the Michigan Department of Environmental Quality has completed a Source Water Assessment for the City of Dowagiac's water wells. This assessment defines the susceptibility of the City's wells to outside contamination. The susceptibility of the City of Dowagiac's wells was ranked Moderately Low for all wells. If you would like to obtain a copy of this Source Water Assessment, please contact Kevin Cox, Water Treatment Plant Superintendent, or Jim Bradford, DPS Director at (269) 782-8200.

Our Water System:

Dowagiac's water source is groundwater drawn from four wells located in Dowagiac. These wells are 12 inches in diameter and approximately 160 feet deep. They provide a clean source of drinking water that is safe to drink without any treatment. This groundwater does contain iron, which may stain laundry and plumbing fixtures. To remove this iron the Dowagiac Water Treatment Plant was constructed in 1974. Approximately 90 % of the iron in the groundwater is removed at the Water Treatment Plant by a filtration process. Other treatment includes addition of chlorine to protect against contamination and addition of fluoride to help prevent tooth decay.

How to Learn More About Our Water System:

If you have any questions about this report or concerning your water utility, please contact Kevin Cox, Water Treatment Plant Superintendent, or Jim Bradford, Department of Public Services Director at (269) 782-8200. We want our valued customers to be informed about their water utility. If you want to learn more, please contact us or attend any of our regularly scheduled City Council meetings. They are held on the second and fourth Monday of each month at 7 P.M. in the council chambers at Dowagiac's City Hall.

General Information About All Drinking Water Sources:

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.
- Radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities.

All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk.

In order to ensure that tap water is safe to drink, the Environmental Protection Agency prescribes regulations, which limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration regulations establish limits for contaminants in bottled water, which must provide the same protection for public health.

- Vulnerability of sub-populations. Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Environmental Protection Agency's State Drinking Water Hotline (800-426-4791).

Tables:

The City of Dowagiac water system routinely monitors for contaminants in your drinking water according to Federal and State laws. Tables on the back of this sheet show the results of our monitoring for the period of January 1, 2014 to December 31, 2014, unless a different date is noted on the table.

Dowagiac Water Treatment Plant Monitoring:

Table of Regulated Detected Contaminants

Substance	Highest Level Allowed (MCL)	Highest Level Detected	Range of Values Detected	EPA Goal (MCLG)	Likely Sources of Contaminant	Year
Fluoride	4.0 ppm	0.55 ppm	0.55 – 0.55 ppm	4.0 ppm	Erosion of natural deposits. Water additive that promotes strong teeth.	2014
Barium	2.0 ppm	0.14 ppm	0.14 – 0.14 ppm	2 ppm	Naturally occurring in some ground-waters	2014
Arsenic	10 ppb	3 ppb	3 – 3 ppb	0 ppb	Naturally occurring in some ground-waters	2014

Note: Dowagiac’s groundwater contains approximately 0.4 ppm of naturally occurring fluoride. Additional fluoride is added at the water treatment plant to bring the level to approximately 0.7 ppm. This is considered the optimum level of fluoride for the prevention of tooth decay.

Substance	Highest MCL Allowed	Highest MCL Detected	Range Detected	Running Annual Average	Likely Sources of Contaminant	Year
Chlorine	4.0 ppm	0.90 ppm	0.00 – 0.90 ppm	0.51 ppm	Added as a disinfectant	2014
Haloacetic Acid	60 ppb	Not Detected	0.0 – 0.0 ppb	0.0 ppb	By-product of drinking water disinfection	2014
Total Trihalomethanes	80 ppb	Not Detected	0.0 – 0.0 ppb	0.0 ppb	By-product of drinking water disinfection	2014

Note: The MCL for total trihalomethanes and haloacetic acids is the sum of the concentrations of the individual trihalomethanes and haloacetic acids. Some people who drink water containing trihalomethanes in excess of the MCL over many years may experience problems with their liver, kidneys, or central nervous system, and may have an increased risk of getting cancer. Some people who drink water containing haloacetic acids in excess of the MCL over many years may have an increased risk of getting cancer.

Substance	Highest Level Allowed (AL)	90 th Percentile Detected	Number of sites found above the AL	EPA Goal	Likely Sources of Contaminant	Year
Copper	1.3 ppm	0.13 ppm	0	1.3 ppm	Corrosion of household plumbing	2012
Lead	15.0 ppb	6 ppb	0	0 ppb	Corrosion of household plumbing	2012

Note: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The City of Dowagiac is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline at 1-800-426-4791 or at <http://water.epa.gov/drink/info/lead/index.cfm>.

**Additional Monitoring:
Table of Unregulated Contaminants**

Substance	Average Level Detected	Range of Values Detected	Likely sources of contaminant	Year
Chloride	15 ppm	15 - 15 ppm	Naturally occurring in some ground-waters	2014
Hardness as CaCO ₃	308 ppm	308 - 308 ppm	Naturally occurring in some ground-waters	2014
Iron	Not detected	Not detected	Naturally occurring in some ground-waters	2014
Nitrate as N	Not detected	Not detected	Septic tank leachate or fertilizers	2014
Nitrite as N	Not detected	Not detected	Septic tank leachate or fertilizers	2014
Sulfate	41 ppm	41 - 41 ppm	Naturally occurring in some ground-waters	2014
Sodium	11 ppm	11 - 11 ppm	Naturally occurring in some ground-waters	2014

In these tables you will find some terms and abbreviations that many people are not familiar with so the following definitions are provided:

- Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.
- Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.
- Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
- Maximum Contaminant Level (MCL) - The "Maximum Allowed" is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology. MCL's are set at very stringent levels. To understand the possible health effects described for many regulated constituents, a person would have to drink 2 liters of water every day at the MCL level for a lifetime to have a one-in-a-million chance of having the described health effect.
- Maximum residual disinfectant level (MRDL) means the level of a drinking water disinfectant below which there is no known or expected risk to health. The MRDL for chlorine is 4.0 mg/L. The chlorine residual levels are calculated based on monthly averages of all samples collected from the water distribution system.
- Maximum residual disinfectant level goal (MRDLG) means the level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLG's do not reflect the benefits of the use of disinfectants to control microbial contaminants. The MRDLG for chlorine is 4.0 mg/L. The MRDLG for TTHM's is 0.
- Maximum Contaminant Level Goal - The "Goal" (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.